


Managing risk on Line 82/95

RIT-T Project Specification Consultation Report

Issue date: 20 September 2024



Disclaimer

This suite of documents comprises Transgrid's application of the Regulatory Investment Test for Transmission (RIT-T) which has been prepared and made available solely for information purposes. It is made available on the understanding that Transgrid and/or its employees, agents and consultants are not engaged in rendering professional advice. Nothing in these documents is a recommendation in respect of any possible investment.

The information in these documents reflect the forecasts, proposals and opinions adopted by Transgrid at the time of publication, other than where otherwise specifically stated. Those forecasts, proposals and opinions may change at any time without warning. Anyone considering information provided in these documents, at any date, should independently seek the latest forecasts, proposals and opinions.

These documents include information obtained from the Australian Energy Market Operator (AEMO) and other sources. That information has been adopted in good faith without further enquiry or verification. The information in these documents should be read in the context of the Electricity Statement of Opportunities, the Integrated System Plan published by AEMO and other relevant regulatory consultation documents. It does not purport to contain all of the information that AEMO, a prospective investor, Registered Participant or potential participant in the National Electricity Market (NEM), or any other person may require for making decisions. In preparing these documents it is not possible, nor is it intended, for Transgrid to have regard to the investment objectives, financial situation and particular needs of each person or organisation which reads or uses this document. In all cases, anyone proposing to rely on or use the information in this document should:

1. Independently verify and check the currency, accuracy, completeness, reliability and suitability of that information
2. Independently verify and check the currency, accuracy, completeness, reliability and suitability of reports relied on by Transgrid in preparing these documents
3. Obtain independent and specific advice from appropriate experts or other sources.

Accordingly, Transgrid makes no representations or warranty as to the currency, accuracy, reliability, completeness or suitability for particular purposes of the information in this suite of documents.

Persons reading or utilising this suite of RIT-T-related documents acknowledge and accept that Transgrid and/or its employees, agents and consultants have no liability for any direct, indirect, special, incidental or consequential damage (including liability to any person by reason of negligence or negligent misstatement) for any damage resulting from, arising out of or in connection with, reliance upon statements, opinions, information or matter (expressed or implied) arising out of, contained in or derived from, or for any omissions from the information in this document, except insofar as liability under any New South Wales and Commonwealth statute cannot be excluded.

Privacy notice

Transgrid is bound by the *Privacy Act 1988 (Cth)*. In making submissions in response to this consultation process, Transgrid will collect and hold your personal information such as your name, email address, employer and phone number for the purpose of receiving and following up on your submissions.

Under the National Electricity Law, there are circumstances where Transgrid may be compelled to provide information to the Australian Energy Regulator (AER). Transgrid will advise you should this occur.

Transgrid's Privacy Policy sets out the approach to managing your personal information. In particular, it explains how you may seek to access or correct the personal information held about you, how to make a complaint about a breach of our obligations under the Privacy Act, and how Transgrid will deal with complaints. You can access the Privacy Policy here (<https://www.transgrid.com.au/Pages/Privacy.aspx>).

Executive summary

We are applying the Regulatory Investment Test for Transmission (RIT-T) to options for mitigating safety, environmental (bushfire) and financial (high reactive maintenance) risks caused by the deteriorating condition of a double circuit transmission line in the Newcastle and Central Coast region. This double circuit 330 kV transmission line runs between Tomago substation and a field location in Seahampton near Newcastle substation, where it splits into the single circuit sections of Line 95 and Line 82. Publication of this Project Specification Consultation Report (PSCR) represents the first step in the RIT-T process.

The 67 structures on the double circuit section of the transmission line covered by this RIT-T span over a route length of 20 km, which traverses mainly bushland and agricultural areas to the west of Newcastle. Specifically, this section is referred to as Line 82/95.

The line is a key part of the network in the Newcastle and Central Coast region and supply infrastructure for Tomago Aluminium.

Detailed analysis of asset condition information has identified that 64 of the 67 structures on Line 82/95 have several condition issues which require refurbishment to address asset health and maintain appropriate risk levels across the network. A significant proportion of the steel transmission structures are impacted by various levels of deterioration and corrosion. Further, recent testing has also identified that some insulators have reached end of life due to deteriorated insulation resistance.

Corrosion increases the likelihood of conductor drops and presents consequent safety and bushfire risk to our personnel and the public, as well as resulting in reactive maintenance costs to repair the failed elements.

Identified need: managing risks on Line 82/95

If action is not taken, the condition of the lines is expected to expose us and our customers to increasing levels of risk going forward, as the likelihood of failure increases. There are safety and bushfire risks under the 'do nothing' base case, as well as higher expected costs associated with reactive maintenance that may be required under emergency conditions ('financial risks').

The proposed investment will enable us to manage these risks on Line 82/95.

Options considered under this RIT-T have been assessed relative to a base case. Under the base case, no proactive capital investment is made and the condition of the lines will continue to deteriorate.

Further condition deterioration of the affected assets due to corrosion would mean an increase in safety and bushfire risks as the likelihood of failure increases. If left untreated, corrosion of some of the vital components of the steel towers could result in incidents such as conductor drop and tower collapse. Such incidents could have safety consequences for nearby residents and members of the public, as well as our field crew who may be working on or near the assets. The lines also cross a major highway and construction site, and therefore have heightened safety consequences.

We manage and mitigate bushfire and safety risk to ensure they are below risk tolerance levels or 'As Low As Reasonably Practicable' ('ALARP'), in accordance with our obligations under the *New South Wales*

Electricity Supply (Safety and Network Management) Regulation 2014 and our Electricity Network Safety Management System (ENSMS).¹

The proposed investment will enable us to continue to manage and operate this part of the network to a safety and risk mitigation level of ALARP. Consequently, it is considered a reliability corrective action under the RIT-T. A reliability corrective action differs from a ‘market benefits’-driven RIT-T in that the preferred option is permitted to have negative net economic benefits on account of it being required to meet an externally imposed obligation on the network business.

We note that the risk cost estimating methodology adopted for this RIT-T aligns with that used in our Revised Revenue Proposal for the 2023-28 period. It reflects feedback from the Australian Energy Regulator (AER) on the methodology initially proposed in our initial Revenue Proposal.

Credible options considered

We have considered two credible options that would meet the identified need from a technical, commercial, and project delivery perspective.² These are summarised in Table E-1.

Table E-1 Summary of credible options

Option	Description	Capital costs (\$m, +/- 25%, Real 2023-24)	Operating costs (per year, Real \$2023-24)
Option 1	Remediate all identified condition issues for line components which have experienced greater deterioration and/or reached the end of their functional lives.	11.5 (± 25%)	14,017
Option 2	Remediate all identified condition issues on the line.	14.6 (± 25%)	14,017

The preferred option is Option 1, as it has the highest weighted NPV result of the technically and commercially feasible options considered at this stage of the RIT-T process. In consideration of the delivery requirements and the economic benefit NPV analysis for the need, its optimal timing is 2026/27.

Non-network options are not expected to assist in this RIT-T

We do not consider non-network options to be commercially and technically feasible to assist with meeting the identified need for this RIT-T, as non-network options will not mitigate the safety and environment (bushfire) risk posed as a result of corrosion-related asset deterioration and deteriorated insulation resistance.

The options have been assessed against three reasonable scenarios

The RIT-T is focused on identifying the top ranked credible option in terms of expected net benefits. However, uncertainty exists in terms of estimating future inputs and variables (termed future ‘states of the world’).

To deal with this uncertainty, the NER requires that costs and market benefits for each credible option are estimated under reasonable scenarios and then weighted based on the likelihood of each scenario to

¹ Our ENSMS follows the International Organization for Standardization’s ISO31000 risk management framework which requires following a hierarchy of hazard mitigation approach

² As per clause 5.15.2(a) of the NER.

determine a weighted ('expected') net benefit. It is this 'expected' net benefit that is used to rank credible options and identify the preferred option.

The credible options have been assessed under three scenarios as part of this PSCR assessment, which differ in terms of the key drivers of the estimated net market benefits (ie, the estimated risk costs avoided).

Given that wholesale market benefits are not relevant for this RIT-T, the three scenarios implicitly assume the most likely scenario from the 2024 ISP (ie, the 'Step Change' scenario). The scenarios differ by the assumed level of risk costs and unserved energy, given that these are key parameters that may affect the ranking of the credible options. Risk cost assumptions do not form part of AEMO's ISP assumptions, and have been based on Transgrid's analysis, as discussed in section 2.

We developed the Central Scenario around a static model of demand scenarios, described further in Section A.3 of our [Network Asset Criticality Framework](#). We consider that this approach is appropriate since it materially reduces the computational effort required, and since differences in demand forecasts will not materially affect the ranking of the credible options.

How the NPV results are affected by changes to other variables (including the discount rate and capital costs) has been investigated in the sensitivity analysis. We consider this is consistent with the latest AER guidance for RIT-Ts of this type (ie, where wholesale market benefits are not expected to be material).^{3, 4, 5}

A summary of the key variables in each scenario is provided in the table below.

Table E-2 Summary of scenarios

Variable / Scenario	Central	Low risk cost scenario	High risk cost scenario risk
Scenario weighting	1/3	1/3	1/3
Discount rate	7%	7%	7%
Network capital costs	Base estimate	Base estimate	Base estimate
Operating and maintenance costs	Base estimate	Base estimate	Base estimate
Safety, environmental and financial risk benefit	Base estimate	Base estimate – 25%	Base estimate +25%

How the NPV results are affected by changes to other variables (including the discount rate and capital costs) has been investigated in sensitivity analysis.

³ AER, *Application Guidelines Regulatory Investment Test for Transmission*, October 2023, pp. 43-44.

⁴ We consider the approach to scenarios and sensitivities to be consistent with the AER guidance provided in November 2022 in the context of the disputes of the North West Slopes and Bathurst, Orange and Parkes RIT-Ts. See: AER, *Decision: North West Slopes and Bathurst, Orange and Parkes Determination on dispute - Application of the regulatory investment test for transmission*, November 2022, pp. 18-20 & 31-32, as well as with the AER's RIT-T Guidelines.


⁵ AEMO '2023 Inputs, Assumptions and Scenarios Report', July 2023, p 123-124

Option 1 delivers the greatest net economic benefits

Under all scenarios, the costs of mitigating the risks under Option 1 are found to be significantly outweighed by the expected benefit of avoiding the risks. This is also true for Option 2, however to a lesser extent.

The net economic benefits delivered by Option 2 are estimated at \$16.9 million.

Figure E-1 Net economic benefits (\$m, PV)



Draft conclusion

Option 1 (remediating all identified condition issues for line components which have experienced greater deterioration and/or reached the end of their functional lives) is the preferred option to meet the identified need at this stage of the RIT-T. Moving forward with this option is the most prudent and economically efficient solution to manage and mitigate safety and environmental risk to ALARP. Consequently, it will ensure our obligations under the *New South Wales Electricity Supply (Safety and Network Management) Regulation 2014* and our Electricity Network Safety Management System (ENSMS) are met.

The estimated capital expenditure associated with this option is \$11.5 million. Routine operating and maintenance costs relating to planned checks by our field crew are \$14,017 per year. We calculate that the avoided risk cost from undertaking Option 1 ranges from approximately \$1.63 million per year to \$5.45 million per year in real terms over the assessment period.

Option 1 is found to have positive net benefits under all scenarios investigated and, on a weighted basis, will deliver \$17.7 million in net economic benefits over the assessment period.

The required works for Option 1, including preparation works, would be undertaken between 2023/24 and 2025/26. All works would be completed in accordance with the relevant standards with minimal modification to the wider transmission assets. Necessary outages of affected line(s) in service would be planned appropriately in order to complete the works with minimal impact on the network.

Exemption from preparing a PADR

Subject to additional credible options being identified during the consultation period, publication of a Project Assessment Draft Report (PADR) is not required for this RIT-T as we consider its investment in relation to the preferred option to be exempt from that part of the process under NER clause 5.16.4(z1). Production of a PADR is not required due to:

- the estimated capital cost of the proposed preferred option being less than \$46 million;
- the PSCR states:
 - the proposed preferred option, together with the reasons for the proposed preferred option;
 - the RIT-T is exempt from producing a PADR; and
 - the proposed preferred option and any other credible option will not have a material market benefit for the classes of market benefit specified in clause 5.16.4(z1)(4), with the exception of market benefits arising from changes in voluntary and involuntary load shedding;
- the RIT-T proponent considers that there were no PSCR submissions identifying additional credible options that could deliver a material market benefit; and
- the PACR must address any issues raised in relation to the proposed preferred option during the PSCR consultation.
- We consider the investment in relation to Option 1 meets these criteria and therefore that we are exempt from producing a PADR under NER clause 5.16.4(z1).

In accordance with NER clause 5.16.4(z1)(4), the exemption from producing a PADR will no longer apply if we consider that an additional credible option that could deliver a material market benefit is identified during the consultation period.

Accordingly, if we consider that any additional credible options are identified, we will produce a PADR which includes an NPV assessment of the net market benefit of each additional credible option.

Should we consider that no additional credible options were identified during the consultation period, we intend to produce a PACR that addresses all submissions received, including any issues in relation to the proposed preferred option raised during the consultation period, and presents our conclusion on the preferred option for this RIT-T.

Submissions and next steps

We welcome written submissions on materials contained in this PSCR. Submissions are due on 19 December 2024⁶.

Submissions should be emailed to our Regulation team via regulatory.consultation@transgrid.com.au.⁷ In the subject field, please reference 'Line 82/95 PSCR'.

At the conclusion of the consultation process, all submissions received will be published on our website. If you do not wish for your submission to be made public, please clearly specify this at the time of lodgement.

⁶ Consultation period is for 12 weeks, additional days have been added to cover public holidays.

⁷ We are bound by the *Privacy Act 1988 (Cth)*. In making submissions in response to this consultation process, we will collect and hold your personal information such as your name, email address, employer and phone number for the purpose of receiving and following up on your submissions. If you do not wish for your submission to be made public, please clearly specify this at the time of lodgement. See Privacy Notice within the Disclaimer for more details.

Subject to additional credible options being identified during consultation, we anticipate publication of a PACR in early 2025.

Contents

Disclaimer	1
Privacy notice	1
Executive summary.....	3
1. Introduction	11
1.1. Purpose of this report	11
1.2. Exemption from preparing a PADR.....	11
1.3. Submissions and next steps	12
2. The identified need	14
2.1. Background to the identified need.....	14
2.2. Description of the identified need.....	17
2.3. Assumptions underpinning the identified need	17
2.3.1. Asset health and the probability of failure	18
2.3.2. Safety risk.....	19
2.3.3. Bushfire risk.....	20
2.3.4. Financial risk.....	20
3. Potential credible options	21
3.1. Base case.....	21
3.2. Option 1 – Line refurbishment limited to components with the greatest deterioration	21
3.3. Option 2 – Line refurbishment addressing all components with condition issues.....	22
3.4. Options considered but not progressed	24
3.5. No material inter-network impact is expected.....	24
4. Non-network options	25
5. Materiality of market benefits	26
5.1. Wholesale electricity market benefits are not material	26
5.2. No other classes of market benefits are material	26
6. Overview of the assessment approach	28
6.1. Description of the base case.....	28
6.2. Assessment period and discount rate.....	28
6.3. Approach to estimating option costs	28
6.4. The options have been assessed against three reasonable scenarios.....	29
6.5. Sensitivity analysis	30

7. Assessment of credible options.....	31
7.1. Estimated gross benefits	31
7.2. Estimated costs	31
7.3. Estimated net economic benefits	31
7.4. Sensitivity testing.....	32
7.4.1. Step 1 – Sensitivity testing of the optimal timing.....	33
7.4.2. Step 2 – Sensitivity of the overall net benefit	33
8. Draft conclusion and exemption from preparing a PADR.....	36
Appendix A Compliance checklist	37
Appendix B Risk Assessment Methodology.....	39
Appendix C Asset Health and Probability of Failure.....	41

1. Introduction

This Project Specification Consultation Report (PSCR) represents the first step in the application of the Regulatory Investment Test for Transmission (RIT-T) to options for mitigating the risks caused by the deteriorating condition of transmission Line 82/95. This 330 kV transmission line links a Tomago substation and a field location in Seahampton near Newcastle substation.

We manage and mitigate bushfire and safety risk to ensure they are below risk tolerance levels or 'As Low As Reasonably Practicable' ('ALARP'), in accordance with our obligations under the *New South Wales Electricity Supply (Safety and Network Management) Regulation 2014* and our Electricity Network Safety Management System (ENSMS).⁸

This RIT-T therefore examines options for addressing the asset condition issues so that network safety continues to meet a risk mitigation level of ALARP. Consequently, it is considered a reliability corrective action under the RIT-T.

1.1. Purpose of this report

The purpose of this PSCR⁹ is to:

- set out the reasons why we propose that action be undertaken (the 'identified need');
- present the options that we currently consider address the identified need;
- outline the technical characteristics that non-network options would need to provide (although we note that non-network options are unlikely to be able to contribute to meeting the identified need for this RIT-T);
- present the economic assessment of all credible options, as well as the assumptions feeding into the analysis, and identify a preferred option at this draft stage of the RIT-T; and
- allow interested parties to make submissions and provide inputs to the RIT-T assessment.

Overall, this report provides transparency into the planning considerations for investment options to ensure continuing reliable supply to our customers. A key purpose of this PSCR, and the RIT-T more broadly, is to provide interested stakeholders the opportunity to review the analysis and assumptions, provide input to the process, and have certainty and confidence that the preferred option has been robustly identified as optimal.

1.2. Exemption from preparing a PADR

Subject to the identification of additional credible options during the consultation period, publication of a Project Assessment Draft Report (PADR) is not required for this RIT-T as we consider that the conditions in clause 5.16.4(z1) of the NER exempting RIT-T proponents from providing a PADR have been met.

Specifically, production of a PADR is not required because:

- the estimated capital cost of the proposed preferred option being less than \$46 million;
- the PSCR states:

⁸ Our ENSMS follows the International Organization for Standardization's ISO31000 risk management framework which requires following a hierarchy of hazard mitigation approach

⁹ See Appendix A for the National Electricity Rules requirements.

- the proposed preferred option, together with the reasons for the proposed preferred option;
- the RIT-T is exempt from producing a PADR; and
- the proposed preferred option and any other credible option will not have a material market benefit for the classes of market benefit specified in clause 5.15A.2(b)(4), with the exception of market benefits arising from changes in voluntary and involuntary load shedding;
- the RIT-T proponent considers that there were no PSCR submissions identifying additional credible options that could deliver a material market benefit; and
- the PACR must address any issues raised in relation to the proposed preferred option during the PSCR consultation.

If an additional credible option that could deliver a material market benefit is identified during the consultation period, then we will produce a PADR that includes an NPV assessment of the net economic benefit of each additional credible option.

If no additional credible options with material market benefits are identified during the consultation period, then the next step in this RIT-T will be the publication of a PACR that addresses all submissions received, including any issues in relation to the proposed preferred option raised during the consultation period.

1.3. Submissions and next steps

We welcome written submissions on materials contained in this PSCR. Submissions are due on 19 December 2024¹⁰.

Submissions should be emailed to our Regulation team via regulatory.consultation@transgrid.com.au.¹¹ In the subject field, please reference 'Line 82/95 PSCR'.

At the conclusion of the consultation process, all submissions received will be published on our website. If you do not wish for your submission to be made public, please clearly specify this at the time of lodgement.


Should we consider that no additional credible options were identified during the consultation period, we intend to produce a Project Assessment Conclusions Report (PACR) that addresses all submissions received, including any issues in relation to the proposed preferred option raised during the consultation period, and presents our conclusion on the preferred option for this RIT-T.¹² Subject to additional credible options being identified, we anticipate publication of a PACR in early 2025.

¹⁰ Consultation period is for 12 weeks.

¹¹ We are bound by the *Privacy Act 1988 (Cth)*. In making submissions in response to this consultation process, we will collect and hold your personal information such as your name, email address, employer and phone number for the purpose of receiving and following up on your submissions. If you do not wish for your submission to be made public, please clearly specify this at the time of lodgement. See Privacy Notice within the Disclaimer for more details.

¹² In accordance with NER clause 5.16.4(z2).

Figure 1-1 This PSCR is the first stage of the RIT-T process¹³



¹³ Australian Energy Market Commission. "[Replacement expenditure planning arrangements, Rule determination](#)". Sydney: AEMC, 18 July 2017.

2. The identified need

This section outlines the identified need for this RIT-T, as well as the assumptions and data underpinning it. It first sets out background information relating to Line 82/95.

2.1. Background to the identified need

Line 82/95 is a double circuit, steel tower 330 kV transmission line between Tomago substation and a field location in Seahampton near Newcastle substation, where it splits into the single circuit sections of Line 95 and Line 82. Line 95 continues on to Newcastle substation, while Line 82 continues on to Liddell substation. The line is a key part of the network in the Newcastle region and supply infrastructure for Tomago Aluminium.

The 67 structures on the double circuit section of the transmission line covered by this RIT-T span over a route length of 20 km, which traverses mainly bushland and agricultural areas to the west of Newcastle. Specifically, this section is referred to as Line 82/95.

Figure 2-1 depicts the location of this line in our Newcastle and Central Coast network.

Figure 2-1 Location of Line 82/95



The line is a key part of the network in the Newcastle and Central Coast region and supply infrastructure for Tomago Aluminium. Detailed analysis of asset condition information has identified that 64 of the 67 structures on Line 82/95 have several condition issues on the line which require refurbishment to address asset health and maintain appropriate risk levels across the network. A significant proportion of the steel transmission structures are impacted by various levels of deterioration and corrosion.

In addition, the insulators have reached the end of their expected lives due to pin corrosion and deterioration of insulator porcelain/polymer material.

Other issues on the line include:

- Corrosion related deterioration on the towers and foundations. Deterioration, particularly of critical members such as tower legs which cannot be readily replaced, can lead to failure and subsequently compromise structural integrity.
- Deterioration of earthwire and conductor fittings, conductor dampers, spacers and corona rings due to corrosion – failure of the fitting attachment can result in a fallen conductor.
- Damaged connections on earthwire bonding and structure earthing – poor connection leads to possible transfer potential, earth current and voltage gradient issues.
- Deterioration on asset components relating to public safety such as climbing deterrents, aerial markers and signage.

Corrosion increases the likelihood of conductor drops and presents consequent safety and bushfire risk to our personnel and the public, as well as resulting in reactive maintenance costs to repair the failed elements. While this is the case for any corroded elements of the transmission network, the bushfire risks are elevated for these lines as the lines traverse substantial sections of bushland.

Figure 2-2,

Figure 2-3 and Figure 2-4 below demonstrate examples of the condition of various components of the transmission lines.

Figure 2-2 Corroded tower bolts and members



Figure 2-3 Corroded fittings



Figure 2-4 Corroded insulator pins



2.2. Description of the identified need

The proposed investment will enable us to manage safety and environmental risks on Line 82/95. Options considered under this RIT-T have been assessed relative to a base case. Under the base case, no proactive capital investment is made and the condition of these lines will continue to deteriorate.

Further deterioration of the condition of the affected assets due to corrosion would mean an increase in safety and bushfire risks as the likelihood of failure increases. If left untreated, corrosion and deterioration of some of the vital components of the steel towers could result in incidents such as conductor drop and tower collapse. As the lines traverse bushland and agricultural areas, the risk of public safety and bushfire incidents from conductor drop or structure failure is increased. Such incidents could have safety consequences for nearby residents and members of the public, as well as field crew members who may be working on or near the assets. The lines also cross a major Highway and construction site, and therefore have heightened safety consequences.

We manage and mitigate bushfire and safety risk to ensure they are below risk tolerance levels or 'As Low As Reasonably Practicable' ('ALARP'), in accordance with our obligations under the *New South Wales Electricity Supply (Safety and Network Management) Regulation 2014* and our Electricity Network Safety Management System (ENSMS).¹⁴

The proposed investment will enable us to continue to manage and operate this part of the network to a safety and risk mitigation level of ALARP. Consequently, it is considered a reliability corrective action under the RIT-T. A reliability corrective action differs from a 'market benefits'-driven RIT-T in that the preferred option is permitted to have negative net economic benefits on account of it being required to meet an externally imposed obligation on the network business.

2.3. Assumptions underpinning the identified need


We adopt a risk cost framework to quantify and evaluate the risks and consequences of increased failure rates. Appendix B provides an overview of our risk assessment methodology.

We note that the risk cost estimating methodology aligns with that used in our revised revenue proposal for the 2023-28 period. It reflects feedback from the Australian Energy Regulator (AER) on the methodology initially proposed in our initial revenue proposal.

Figure 2-5 summarises the increasing risk costs over the assessment period under the base case.

¹⁴ Our ENSMS follows the International Organization for Standardization's ISO31000 risk management framework which requires following a hierarchy of hazard mitigation approach

Figure 2-5 Estimated risk costs under the central scenario (\$m, real 2023/24)



This section describes the assumptions underpinning our assessment of the base case risk costs, ie, the value of the risk avoided by undertaking the credible options below. The aggregate risk cost is estimated at around \$1.63 million/year currently in 2024, and it is expected to increase going forward if action is not taken and the lines are left to deteriorate further (reaching approximately \$5.45 million/year by 2043).

2.3.1. Asset health and the probability of failure

Our asset health modelling aligns with Chapter 5.2 of the AER’s asset replacement planning guideline.¹⁵ Condition information for each asset is assessed to generate an Asset Health Index and assets in relatively poor condition, as identified through the asset health index, are candidates for a replacement or refurbishment intervention.

The asset health issues identified on Line 82/95 and their consequences are summarised in Table 2-1.

¹⁵ AER, *Industry practice application note – Asset replacement planning*, January 2019 – available at <https://www.aer.gov.au/system/files/D19-2978%20-%20AER%20-Industry%20practice%20application%20note%20Asset%20replacement%20planning%20-%2025%20January%202019.pdf>

Table 2-1 Asset health issues along Line 82/95 and their consequences

Issue	Consequences if not remediated
Corrosion of tower steel bolts and members	Structural failure, leading to bushfire, safety and financial risks
Corrosion of foundation interfaces	
Corrosion and deterioration of insulators	Conductor drop, leading to bushfire, safety and financial risks
Corrosion of conductor attachment fittings	
Conductor spacers and corona rings	
Damaged earthwire bonding connection	
Corrosion of earthwire attachment fittings	
Conductor dampers deteriorated	
Deteriorated earthing	Increased public safety risk
Deteriorated climbing deterrents and signage	

Asset health is used to estimate the remaining life of an asset and forecast the associated probability of failure (PoF) of the asset now and into the future. The future health of an asset (health forecasting) is a function of its current health and any factors causing accelerated (or decelerated) degradation or ‘age shifting’ of one or more of its components. Such moderating factors can represent the cumulative effects arising from continual or discrete exposure to unusual events, external stresses, overloads and faults.

Asset condition information is the primary source of information on the current health of the transmission line and its components. Condition information obtained through routine inspections of transmission lines, such as condition rating of each component, and asset information, such as natural age, location and ideal life expectancy, form the basis for deriving current health.

The PoF is the likelihood that an asset will fail during a given period resulting in a particular adverse event. The probability of each failure mode is calculated using reliability engineering techniques that take into account conditional age (chronological age moderated by asset health), failure and defect history, and industry benchmarking studies. We screen out failures that are not related to end-of-life when quantifying risk for replacement projects because such risks are not addressed by these works.

2.3.2. Safety risk

This risk refers to the safety consequence to members of the public of an asset failure whose failure modes can create harm. The estimated value takes into account the cost associated with a fatality or injury including compensation, loss of productivity, litigation fees, fines and any other related costs.

Our safety model has recently been updated and developed in conjunction with asset management specialist consultancy AMCL¹⁶. The main changes to the model relate to consequence and likelihood quantifications with our safety risk now considering a range of consequences, from minor injury to fatality, and the likelihood of each based on historical events, human movement data and land use.

Consistent with our ALARP obligations, we apply a disproportionality factor of ‘six’ to the public safety component and ‘three’ to the worker safety component of safety risk.

¹⁶ Refer to [Network Asset Criticality Framework](#)

Safety risk makes up approximately 21 per cent of the total estimated risk cost in present value terms under the base case for this RIT-T.

2.3.3. Bushfire risk

This risk refers to the consequence to the community of an asset failure that results in a bushfire starting. We recently undertook assessment with the University of Melbourne¹⁷ to improve our quantification of bushfire risks across our network, including the moderation of risk costs, using an electricity industry-developed approach.

The bushfire risk model:

- models the potential spread from a fire started at each asset in the network using recognised fire modelling software;
- calculates the consequence based on the number of houses, agricultural and forestry land use (and other infrastructure in the predicted burn area);
- moderates the consequence using a statistical distribution of fire conditions across the year to come up with a most likely consequence to be used in the investment decision;
- moderates this likely consequence by the likelihood of network assets igniting a fire in the event a catastrophic asset failure occurs (i.e., not all asset failures will ignite a fire); and
- further moderates this likely consequence taking in to account the expected emergency services response to a fire based on the proximity to population (i.e., locations close to population centres have the highest moderation of likely consequence as the emergency services response is expected to be relatively expeditious).

Consistent with our ALARP obligations, we apply a disproportionality factor of ‘six’ to the bushfire risk.¹⁸

Bushfire risk makes up approximately 76 per cent of the total estimated risk cost in present value terms under the base case for this RIT-T.

2.3.4. Financial risk

This risk refers to the direct financial consequence arising from the failure of an asset including the cost of replacement or repair of the asset (reactive maintenance) which may need to be under emergency conditions.

Financial risk makes up approximately 3 per cent of the total estimated risk cost in present value terms under the base case for this RIT-T.

¹⁷ Refer to [Network Asset Criticality Framework](#)

¹⁸ Refer to section 6.2.5 of the [Network Risk Assessment Methodology](#)

3. Potential credible options

This section describes the options we have explored to address the need, including the scope of each option and the associated costs.

We consider that there are three feasible options from a technical, commercial, and project delivery perspective that can be implemented in sufficient time to meet the identified need. Four other options were considered but not progressed for various reasons that are outlined in Table 3-3.

All costs and benefits presented in this PSCR are in 2023/24 dollars, unless otherwise stated.

3.1. Base case

The costs and benefits of each option in this PSCR are compared against those of a base case¹⁹. Under this base case, no proactive capital investment is made to remediate the deterioration of the identified assets and the lines will continue to operate and be maintained under the current regime.

While the base case is not a situation we plan to encounter, and this RIT-T has been initiated specifically to avoid it, the assessment is required under the RIT-T to use this base case as a common point of reference when estimating the net benefits of each credible option.

The regular maintenance regime will not be able to mitigate the risk of asset failure that will expose us and end-customers to approximately \$2.2 million per year in safety, environmental and financial risk costs by 2028, rising to \$5.45 million per year by 2042.²⁰ The environmental and safety risk costs are mainly due to the significant consequences of a bushfire event resulting from conductor drop or structure failure and risks associated with compromised earthing. Under the base case, all of these risks will continue to increase.

The annual transmission line routine operating expenditure under the base case is \$14,017. We do not expect this to change with any of the investment options being considered, since the options will not change the frequency of planned inspections (however, the reactive maintenance costs do differ and are captured under financial risks).

3.2. Option 1 – Line refurbishment limited to components with the greatest deterioration

Option 1 involves the remediation Line 82/95 to address only the components that have experienced the greatest deterioration and/or have reached the end of their functional lives, to prevent failure in the short term.

Details of the scope of works under Option 1 are summarised in Table 3-1.

¹⁹ AER, Application Guidelines Regulatory Investment Test for Transmission, October 2023, pp. 22-23.

²⁰ This determination of yearly risk costs is based on our Network Asset Risk Assessment Methodology and incorporates variables such as likelihood of failure/exposure, various types of consequence costs and corresponding likelihood of occurrence.

Table 3-1 Option 1 scope of works

Issue	Remediation	Scope Quantity
Corrosion of tower members	Replacement or refurbishment of tower members	1
Corrosion of tower fasteners	Replacement of tower nut and bolt fasteners	11,000
Foundations	Remediation of tower/pole base and foundations	31
Corrosion and deterioration of insulators	Replacement of complete insulator arrangement	49
Corrosion of conductor attachment fittings	Replacement of complete insulator arrangement	22
Conductor spacers and corona rings	Replacement of spacers and corona rings	16
Damaged earthwire bonding connection	Replacement of earthwire bonding	11
Corrosion of earthwire attachment fittings	Replacement of fittings	21
Conductor dampers deteriorated	Replacement of dampers	24
Deteriorated earthing	Replacement of tower/pole earths	5
Corrosion of tower steelwork	Blasting and painting of tower body	7
Deteriorated tower ladder	Replacement of tower ladder	5
Deteriorated climbing deterrents and signage	Replacement of public safety devices	67

The works are expected to be undertaken between 2023/24 and 2025/26. Planning, design, development and procurement (including completion of the RIT-T) will occur between 2023/24 and 2024/25, while project delivery and construction will occur from 2024/25.

All works would be completed in accordance with the relevant standards by 2026/27 with minimal modification to the wider transmission assets. Necessary outages of affected line(s) in service would be planned appropriately in order to complete the works with minimal impact on the network.

The estimated capital expenditure associated with this option is \$11.5 million. Routine operating and maintenance costs are the same as the base case for this option (estimated at \$14,017 per year).

This option has the lowest estimated risk reduction due to it being a 'minimal scope' option designed to only address the components that have experienced the greatest deterioration and have reached the end of their functional lives to prevent failure in the short-term.

3.3. Option 2 – Line refurbishment addressing all components with condition issues

Option 2 involves the refurbishment of Line 82/95 to address all components that have been identified with condition issues, to prevent failure in the short and medium-term (ie, rather than only the components which have experienced the greatest deterioration).

Details of the scope of works under Option 2 are summarised in Table 3-1. Remediation activities that are greater than the equivalent for Option 1 are shaded in grey.

Table 3-2 Option 2 scope of works

Issue	Remediation	Scope Quantity
Corrosion of tower/pole steel members	Replacement or refurbishment of tower members	17
Corrosion of tower fasteners	Replacement of tower nut and bolt fasteners	11,000
Foundations	Remediation of tower/pole base and foundations	31
Corrosion and deterioration of insulators	Replacement of complete insulator arrangement	49
Corrosion of conductor attachment fittings	Replacement of complete insulator arrangement	28
Conductor spacers and corona rings	Replacement of spacers and corona rings	540
Damaged earthwire bonding connection	Replacement of earthwire bonding	11
Corrosion of earthwire attachment fittings	Replacement of fittings	21
Conductor dampers deteriorated	Replacement of dampers	48
Deteriorated earthing	Replacement of tower/pole earths	5
Corrosion of tower steelwork	Blasting and painting of tower body	10
Deteriorated tower ladder	Replacement of tower ladder	5
Deteriorated climbing deterrents and signage	Replacement of public safety devices	67

The works are expected to be undertaken between 2023/24 and 2025/26. Planning, design, development and procurement (including completion of the RIT-T) will occur between 2023/24 and 2024/25, while project delivery and construction will occur from 2024/25.

All works would be completed in accordance with the relevant standards by 2026/27 with minimal modification to the wider transmission assets. Necessary outages of affected line(s) in service would be planned appropriately in order to complete the works with minimal impact on the network.

The estimated capital expenditure associated with this option is \$14.6 million. Routine operating and maintenance costs are the same as the base case for this option (estimated at \$14,017 per year).

This option has greater estimated risk reduction than Option 1 due to it addressing all identified components with condition issues.

3.4. Options considered but not progressed

Table 3-3 summarises the reasons the following credible options were not progressed further.

Table 3-3 Options considered but not progressed

Description	Reason(s) for not progressing
Increased inspections	The condition issues have already been identified and cannot be rectified through increased inspections, and therefore is not technically feasible.
Elimination of all associated risk	This can only be achieved through retirement and decommissioning of the associated assets which may lead to reliability issue. Therefore, it is not considered technically feasible.
New transmission line	Due to significant costs of this option, a new double circuit 330 kV transmission line is not considered commercially feasible.
Non-network solutions	Transgrid does not consider non-network options to be commercially and technically feasible to assist with meeting the identified need, as non-network options will not mitigate the environment (bushfire) and safety posed as a result of corrosion-related asset deterioration and deteriorated insulation resistance.

3.5. No material inter-network impact is expected

We have considered whether the credible option listed above is expected to have material inter-regional impact.²¹ A ‘material inter-network impact’ is defined in the NER as:

“A material impact on another Transmission Network Service Provider’s network, which impact may include (without limitation): (a) the imposition of power transfer constraints within another Transmission Network Service Provider’s network; or (b) an adverse impact on the quality of supply in another Transmission Network Service Provider’s network.”

AEMO’s suggested screening test to indicate that a transmission augmentation has no material inter-network impact is that it satisfies the following:²²

- a decrease in power transfer capability between transmission networks or in another TNSP’s network of no more than the minimum of 3% of the maximum transfer capability and 50 MW;
- an increase in power transfer capability between transmission networks or in another TNSP’s network of no more than the minimum of 3% of the maximum transfer capability and 50 MW;
- an increase in fault level by less than 10 MVA at any substation in another TNSP’s network; and
- the investment does not involve either a series capacitor or modification in the vicinity of an existing series capacitor.

We note that each credible option satisfies these conditions as it does not modify any aspect of electrical or transmission assets. By reference to AEMO’s screening criteria, there is no material inter-network impacts associated with any of the credible options considered.

²¹ As per clause 5.16.4(b)(6)(ii) of the NER.

²² Inter-Regional Planning Committee. *“Final Determination: Criteria for Assessing Material Inter-Network Impact of Transmission Augmentations.”* Melbourne: Australian Energy Market Operator, 2004. Appendix 2 and 3. Accessed 08 May 2024. <https://www.aemo.com.au/-/media/Files/PDF/170-0035-pdf>

4. Non-network options

We do not consider non-network options to be commercially and technically feasible to assist with meeting the identified need for this RIT-T, as non-network options will not mitigate the safety and environment risk posed as a result of corrosion-related asset deterioration and deteriorated insulation resistance. This is based on:

- the fact that the identified need for this investment is not driven by avoiding potential unserved energy so that no amount of demand reduction would defer or avoid the preferred network option – irrespective of the size, nature and location of the non-network option; and
- any non-network solution for this need is expected to only add to the costs of this option. That is, non-network options would not provide any net benefits.

5. Materiality of market benefits

This section outlines the categories of market benefits prescribed in the National Electricity Rules (NER) and whether they are considered material for this RIT-T.²³

5.1. Wholesale electricity market benefits are not material

The AER has recognised that if the credible options considered will not have an impact on the wholesale electricity market, then a number of classes of market benefits will not be material in the RIT-T assessment, and so do not need to be estimated.²⁴

The credible options considered in this RIT-T will not address network constraints between competing generating centres and are therefore not expected to result in any change in dispatch outcomes and wholesale market prices. We therefore consider that the following classes of market benefits are not material for this RIT-T assessment:

- changes in fuel consumption arising through different patterns of generation dispatch;
- changes in voluntary load curtailment (since there is minor impact on pool price);
- changes in costs for parties other than the RIT-T proponent;
- changes in ancillary services costs;
- changes in network losses; and
- competition benefits.

5.2. No other classes of market benefits are material

In addition to the classes of market benefits listed above, NER clause 5.16.1(c)(4) requires that we consider the following classes of market benefits, listed in Table 5-1, arising from each credible option. We consider that none of the classes of market benefits listed are material for this RIT-T assessment for the reasons in Table 5-1.

²³ The NER requires that all classes of market benefits identified in relation to the RIT-T are included in the RIT-T assessment, unless the TNSP can demonstrate that a specific class (or classes) is unlikely to be material in relation to the RIT-T assessment for a specific option – NER clause 5.16.1(c)(6). See Appendix A for requirements applicable to this document.

²⁴ AER, *Application Guidelines Regulatory Investment Test for Transmission*, October 2023.

Table 5-1 Reasons non-wholesale electricity market benefits are considered immaterial

Market benefits	Reason
Changes in involuntary load curtailment	Since Line 82/95 forms part of a meshed network (N-1 redundant) required to supply the Newcastle and Central Coast region, a failure of one or both lines due to condition issues results in a negligible chance of unserved energy.
Differences in the timing of expenditure	Options considered will provide an alternative to meeting reliability requirements but are unlikely to affect decisions to undertake unrelated expenditure in the network. Consequently, material market benefits will neither be gained nor lost due to changes in the timing of other network expenditure from any of the options considered.
Option value	<p>We note the AER's view that option value is likely to arise where there is uncertainty regarding future outcomes, the information that is available is likely to change in the future, and the credible options considered by the TNSP are sufficiently flexible to respond to that change.²⁵</p> <p>We also note the AER's view that appropriate identification of credible options and reasonable scenarios captures any option value, thereby meeting the NER requirement to consider option value as a class of market benefit under the RIT-T.</p> <p>We note that no credible option is sufficiently flexible to respond to change or uncertainty for this RIT-T. Specifically, each option is focused on proactively replacing deteriorating assets ahead of when they fail.</p>
Changes in Australian greenhouse gas emissions	Neither option is expected to induce a material change in Australia's greenhouse gas emissions.

²⁵ AER, *Application Guidelines Regulatory Investment Test for Transmission*, October 2023.

6. Overview of the assessment approach

This section outlines the approach that we have applied in assessing the net benefits associated with each of the credible options against the base case.

6.1. Description of the base case

The costs and benefits of each option are compared against the base case. Under this base case, no investment is undertaken, we incur regular and reactive maintenance costs, and the line will continue to operate with an increasing level of risk.

We note that this course of action is not expected in practice. However, this approach has been adopted since it is consistent with AER guidance on the base case for RIT-T applications.²⁶

6.2. Assessment period and discount rate

A 20-year assessment period from 2023/24 to 2042/43 has been adopted for this RIT-T analysis. This period takes into account the size, complexity and expected asset life of the options.

Where the capital components of the credible options have asset lives extending beyond the end of the assessment period, the NPV modelling includes a terminal value to capture the remaining asset life. This ensures that the capital cost of long-lived options over the assessment period is appropriately captured, and that all options have their costs and benefits assessed over a consistent period, irrespective of option type, technology or asset life. The terminal values are calculated as the undepreciated value of capital costs at the end of the analysis period.

A real, pre-tax discount rate of 7 per cent has been adopted as the central assumption for the NPV analysis presented in this PSCR, consistent with the assumptions adopted in AEMO's 2024 Integrated System Plan (ISP).²⁷ The RIT-T requires that sensitivity testing be conducted on the discount rate and that the regulated weighted average cost of capital (WACC) be used as the lower bound. We have therefore tested the sensitivity of the results to a lower bound discount rate of 3.63 per cent.²⁸ We have adopted an upper bound discount rate of 10.50 per cent (ie, AEMO's 2023 Inputs, Assumptions and Scenarios Report).²⁹

6.3. Approach to estimating option costs

We have estimated the capital costs of the options based on the scope of works necessary together with costing experience from previous projects of a similar nature.

The cost estimates are developed using our 'MTWO' cost estimating system. This system utilises historical average costs, updated by the costs of the most recently implemented project with similar scope. All

²⁶ We note that the AER RIT-T Guidelines state that the base case is where the RIT-T proponent does not implement a credible option to meet the identified need, but rather continues its 'BAU activities'. The AER define 'BAU activities' as ongoing, economically prudent activities that occur in the absence of a credible option being implemented. Australian Energy Regulator. "Application guidelines Regulatory Investment for Transmission, October 2023"

²⁷ AEMO, 2024 Integrated System Plan, June 2024, p 92.

²⁸ This is equal to WACC (pre-tax, real) in the latest final decision for a transmission business in the NEM (Transgrid) as of the date of this analysis, see: AER, TasNetworks – 2024-29 – Final decision – PTRM, April 2024, WACC sheet.

²⁹ AEMO '2023 Inputs, Assumptions and Scenarios Report', July 2023, p 123.

estimates in MTWO are developed to deliver a 'P50' portfolio value for a total program of works (i.e., there is an equal likelihood of over- or under-spending the estimate total).³⁰

We estimate the majority of structures will be refurbished in normal soil. As work is to refurbish structures on an existing line, minor access track upgrade work, water crossing upgrades, ground work in the form of grade and filling, and vegetation clearing have been allowed for.

We estimate that actual costs will be within +/- 25 per cent of the central capital cost estimate. An accuracy of +/-25 per cent for cost estimates is consistent with industry best practice and aligns with the accuracy range of a 'Class 4' estimate, as defined in the Association for the Cost Engineering classification system.

All cost estimates are prepared in real, 2023/24 dollars based on the information and pricing history available at the time that they were estimated. The cost estimates do not include or forecast any real cost escalation for materials.

Routine operating and maintenance costs are based on works of similar nature.

6.4. The options have been assessed against three reasonable scenarios

The RIT-T is focused on identifying the top ranked credible option in terms of expected net benefits. However, uncertainty exists in terms of estimating future inputs and variables (termed future 'states of the world').

To deal with this uncertainty, the NER requires that costs and market benefits for each credible option are estimated under reasonable scenarios and then weighted based on the likelihood of each scenario to determine a weighted ('expected') net benefit. It is this 'expected' net benefit that is used to rank credible options and identify the preferred option.

The credible options have been assessed under three scenarios as part of this PSCR assessment, which differ in terms of the key drivers of the estimated net market benefits (ie, the estimated risk costs avoided).

Given that wholesale market benefits are not relevant for this RIT-T, the three scenarios implicitly assume the most likely scenario from the 2024 ISP (ie, the 'Step Change' scenario). The scenarios differ by the assumed level of risk costs and unserved energy, given that these are key parameters that may affect the ranking of the credible options. Risk cost assumptions do not form part of AEMO's ISP assumptions, and have been based on Transgrid's analysis, as discussed in section 2.

We developed the Central Scenario around a static model of demand scenarios, described further in Section A.3 of our [Network Asset Criticality Framework](#). We consider that this approach is appropriate since it materially reduces the computational effort required, and since differences in demand forecasts will not materially affect the ranking of the credible options.

How the NPV results are affected by changes to other variables (including the discount rate and capital costs) has been investigated in the sensitivity analysis. We consider this is consistent with the latest AER

³⁰ For further detail on our cost estimating approach refer to section 7 of our [Augmentation Expenditure Overview Paper](#) submitted with our 2023-28 Revenue Proposal.

guidance for RIT-Ts of this type (ie, where wholesale market benefits are not expected to be material).^{31, 32, 33}

Table 6-1 Summary of scenarios

Variable / Scenario	Central	Low risk cost scenario	High risk cost scenario risk
Scenario weighting	1/3	1/3	1/3
Discount rate	7%	7%	7%
Network capital costs	Base estimate	Base estimate	Base estimate
Operating and maintenance costs	Base estimate	Base estimate	Base estimate
Safety, environmental and financial risk benefit	Base estimate	Base estimate – 25%	Base estimate +25%

We have weighted the three scenarios equally given there is nothing to suggest an alternate weighting would be more appropriate.

6.5. Sensitivity analysis

In addition to the scenario analysis, we have also considered the robustness of the outcome of the cost benefit analysis through undertaking a range of sensitivity testing, focused on the central scenario.

The range of factors tested as part of the sensitivity analysis in this PSCR are:

- lower and higher capital costs of the credible options;
- lower and higher estimated safety, environmental and financial risk benefits; and
- alternate commercial discount rate assumptions.

The above list of sensitivities focuses on the key variables that could impact the identified preferred option. The results of the sensitivity tests are set out in section 7.4.

In addition, we have also sought to identify the 'boundary value' for key variables beyond which the outcome of the analysis would change, including the amount by which capital costs would need to increase for the preferred option to no longer be preferred.

³¹ AER, Application Guidelines Regulatory Investment Test for Transmission, October 2023, pp. 43-44.

³² We consider the approach to scenarios and sensitivities to be consistent with the AER guidance provided in November 2022 in the context of the disputes of the North West Slopes and Bathurst, Orange and Parkes RIT-Ts. See: AER, *Decision: North West Slopes and Bathurst, Orange and Parkes Determination on dispute - Application of the regulatory investment test for transmission*, November 2022, pp. 18-20 & 31-32, as well as with the AER's RIT-T Guidelines.

³³ AEMO '2023 Inputs, Assumptions and Scenarios Report', July 2023, p 123-124

7. Assessment of credible options

This section outlines the assessment we have undertaken of the credible network options. The assessment compares the costs and benefits of each credible option to the base case. The benefits of each credible option are represented by a reduction in costs or risks compared to the base case.

All costs and benefits presented in this PSCR are in 2023/24 dollars.

7.1. Estimated gross benefits

Figure 7-1 below summarises the present value of the gross benefits of the options under the three scenarios. These include both the avoided risk cost estimates for each credible option relative to the base case.

Table 7-1 Estimated gross benefits from credible options relative to the base case (\$m, PV)

Option/scenario	Central	Low risk cost scenario	High risk cost scenario	Weighted
<i>Scenario weighting</i>	33%	33%	33%	
Option 1	25.37	19.03	31.71	25.37
Option 2	25.53	19.15	31.91	25.53

7.2. Estimated costs

Table 7-2 below summarises the costs of the options, relative to the base case, in present value terms. The cost includes the direct capital and routine operating costs of each option, relative to the base case, and is the same for each option in all scenarios given nothing that affects the direct costs is varied between scenarios.

Table 7-2 Costs of credible options relative to the base case (\$m, PV)

Option/Scenario	Cost
Option 1	8.50
Option 2	10.76


7.3. Estimated net economic benefits

The net economic benefits are the differences between the estimated gross benefits and the estimated costs. Table 7-3 below summarises the present value of the net economic benefits for both Options are found to have positive net benefits for all scenarios investigated. On a weighted basis, Option 1 is found to deliver approximately \$16.87 million and Option 2 approximately \$14.77 million.

Table 7-3 Net economic benefits for Option 1 relative to the base case (\$m, PV)

Option	Central	Low risk cost scenario	High risk cost scenario	Weighted
Scenario weighting	33%	33%	33%	
Option 1	16.87	10.53	23.21	16.87
Option 2	14.77	8.39	21.15	14.77

Figure 7-1 Net economic benefits (\$m, PV)



7.4. Sensitivity testing

We have undertaken sensitivity testing to understand the robustness of the RIT-T assessment to underlying assumptions about key variables. In particular, we have undertaken two sets of sensitivity tests:

- Step 1 – testing the sensitivity of the optimal timing of the project (‘trigger year’) to different assumptions in relation to key variables; and
- Step 2 – once a trigger year has been determined, testing the sensitivity of the total NPV benefit associated with the investment proceeding in that year, in the event that actual circumstances turn out to be different.

Having assumed to have committed to the project by this date, we have also looked at the consequences of ‘getting it wrong’ under step 2 of the sensitivity testing. That is, if expected safety and environmental risks are not as high as expected, for example, the impact on the net economic benefit associated with the project continuing to go ahead on that date.

The application of the two steps to test the sensitivity of the key findings is outlined below.

7.4.1. Step 1 – Sensitivity testing of the optimal timing

This section outlines the sensitivity of the identification of the commissioning year of Option 1 to changes in the underlying assumptions. In particular, the optimal timing of Option 1 is found to be invariant to the assumptions of:

- a 25 per cent increase/decrease in the assumed network capital costs;
- lower discount rate of 3.63 per cent as well as a higher rate of 10.5 per cent; and
- lower (or higher) assumed safety, environmental and financial risks.

Each timing sensitivity has been undertaken on the central scenario.

Figure 7.2 below outlines the impact on the optimal commissioning year, under a range of alternative assumptions. It illustrates that for Option 1, the optimal commissioning date is found to be in 2026/27 for all of the sensitivities investigated.

The optimal timing for Option 1 is also invariant to all of the above assumptions.

Figure 7.2 Optimal timing of Option 1.



7.4.2. Step 2 – Sensitivity of the overall net benefit

We have conducted sensitivity analysis on the present value of the net economic benefit, based on undertaking the project by 2025/26. Specifically, we have investigated the same sensitivities under this step as in the first step:

- a 25 per cent increase/decrease in the assumed network capital costs;
- lower discount rate of 3.63 per cent as well as a higher rate of 10.5 per cent; and
- lower (or higher) assumed safety, environmental and financial risks.

All these sensitivities investigate the consequences of ‘getting it wrong’ having committed to a certain investment decision.

The figures below illustrate the estimated net economic benefits for each option if separate key assumptions in the central scenario are varied individually. Both options deliver positive benefits under all scenarios.

The sensitivity testing focuses on the central scenario given the ranking of the options is found to be the same across all three scenarios investigated and there are significant expected net market benefits under each scenario. That is, we do not expect the key findings to change for this RIT-T if the sensitivity testing was expanded to cover the low risk and high risk scenarios.

Figure 7-3 Capital cost sensitivity




Figure 7-4 Commercial discount rate sensitivity





Figure 7-5 Risk costs sensitivity



Our results suggests that there is no reasonable change in discount rate, assumed network capital costs, or estimated risk costs that would change the expected net benefit to negative, we therefore consider the expected positive net benefits provided by Option 1 to be robust to reasonable capital cost sensitivities.

In terms of boundary testing, we find that the following would need to occur for Option 1 to have net market benefits equal to that of Option 2:

- assumed network capital costs (for all options) would need to decrease by 91 per cent;
- the estimated risk costs (in aggregate) would need to fall by over 1000 per cent; and
- a discount rate would need to be greater than 100 per cent.

We therefore consider the finding that Option 1 is preferred over Option 2 to be robust to the key underlying assumptions.

8. Draft conclusion and exemption from preparing a PADR

This PSCR has found that Option 1 is the preferred option at this draft stage of the RIT-T.

Option 1 involves:

- remediating all identified condition issues for line components which have experienced greater deterioration and/or reached the end of their functional lives.

The estimated capital expenditure associated with this option is \$11.5 million. Routine operating and maintenance costs relating to planned checks by our field crew are \$14,017 per year. The works are expected to be undertaken between 2023/24 and 2025/26. Planning, design, development and procurement (including completion of the RIT-T) will occur between 2023/24 and 2024/25, while project delivery and construction will occur from 2024/25. Project completion is assumed by 2026/27.

Subject to the identification of additional credible options during the consultation period, publication of a Project Assessment Draft Report (PADR) is not required for this RIT-T as we consider that the conditions in clause 5.16.4(z1) of the NER exempting RIT-T proponents from providing a PADR have been met.

Specifically, production of a PADR is not required because:

- the estimated capital cost of the proposed preferred option being less than \$46 million³⁴;
- the PSCR states:
 - the proposed preferred option, together with the reasons for the proposed preferred option;
 - the RIT-T is exempt from producing a PADR; and
 - the proposed preferred option and any other credible option will not have a material market benefit for the classes of market benefit specified in clause 5.16.4(z1), with the exception of market benefits arising from changes in voluntary and involuntary load shedding;
- the RIT-T proponent considers that there were no PSCR submissions identifying additional credible options that could deliver a material market benefit; and
- the PACR must address any issues raised in relation to the proposed preferred option during the PSCR consultation.

If an additional credible option that could deliver a material market benefit is identified during the consultation period, then we will produce a PADR that includes an NPV assessment of the net economic benefit of each additional credible option.

If no additional credible options with material market benefits are identified during the consultation period, then the next step in this RIT-T will be the publication of a PACR that addresses all submissions received, including any issues in relation to the proposed preferred option raised during the consultation period.³⁵

³⁴ Varied from \$43m to \$46m based on the [AER Final Determination: Cost threshold review](#) November 2021.

³⁵ In accordance with NER clause 5.16.4(z2).

Appendix A Compliance checklist

This appendix sets out a checklist which demonstrates the compliance of this PSCR with the requirements of the National Electricity Rules version 216.

Rules clause	Summary of requirements	Relevant section
5.16.4 (b)	A RIT-T proponent must prepare a report (the project specification consultation report), which must include:	–
	(1) a description of the identified need;	2
	(2) the assumptions used in identifying the identified need (including, in the case of proposed reliability corrective action, why the RIT-T proponent considers reliability corrective action is necessary);	2
	(3) the technical characteristics of the identified need that a non-network option would be required to deliver, such as: <ul style="list-style-type: none"> (i) the size of load reduction of additional supply; (ii) location; and (iii) operating profile; 	4
	(4) if applicable, reference to any discussion on the description of the identified need or the credible options in respect of that identified need in the most recent National Transmission Network Development Plan;	NA
	(5) a description of all credible options of which the RIT-T proponent is aware that address the identified need, which may include, without limitation, alternative transmission options, interconnectors, generation, demand side management, market network services or other network options;	3
	(6) for each credible option identified in accordance with subparagraph (5), information about: <ul style="list-style-type: none"> (i) the technical characteristics of the credible option; (ii) whether the credible option is reasonably likely to have a material inter-network impact; (iii) the classes of market benefits that the RIT-T proponent considers are likely not to be material in accordance with clause 5.16.1(c)(6), together with reasons of why the RIT-T proponent considers that these classes of market benefit are not likely to be material; (iv) the estimated construction timetable and commissioning date; and (v) to the extent practicable, the total indicative capital and operating and maintenance costs. 	3 & 5

<p>5.16.4(z1)</p>	<p>A RIT-T proponent is exempt from [preparing a PADR] (paragraphs (j) to (s)) if:</p> <ol style="list-style-type: none"> 1. the estimated capital cost of the proposed preferred option is less than \$35 million³⁶ (as varied in accordance with a cost threshold determination); 2. the relevant Network Service Provider has identified in its project specification consultation report: <ol style="list-style-type: none"> (i) its proposed preferred option; (ii) its reasons for the proposed preferred option; and (iii) that its RIT-T project has the benefit of this exemption; 3. the RIT-T proponent considers, in accordance with clause 5.16.1(c)(6), that the proposed preferred option and any other credible option in respect of the identified need will not have a material market benefit for the classes of market benefit specified in clause 5.16.1(c)(4) except those classes specified in clauses 5.16.1(c)(4)(ii) and (iii), and has stated this in its project specification consultation report; and 4. the RIT-T proponent forms the view that no submissions were received on the project specification consultation report which identified additional credible options that could deliver a material market benefit. 	<p>8</p>
-------------------	--	----------

³⁶ Varied to \$46m based on the AER Final Determination: Cost threshold review November 2021. Accessed 08 May 2024 <https://www.aer.gov.au/networks-pipelines/guidelines-schemes-models-reviews/cost-thresholds-review-for-the-regulatory-investment-tests-2021>

Appendix B Risk Assessment Methodology


This appendix summarises our network risk assessment methodology that underpins the identified need for this RIT-T. Our risk assessment methodology is aligned with the AER’s Asset Replacement Planning guideline³⁷ and its principles.

A fundamental part of the risk assessment methodology is calculating the annual ‘risk costs’ or the monetised impacts of the reliability, safety, bushfire, environmental and financial risks.

The monetary value of risk (per year) for an individual asset failure resulting in an undesired outcome, is the likelihood (probability) of failure (in that year with respect to its age), as determined through modelling the failure behaviour of an asset (Asset Health), multiplied by the consequence (cost of the impact) of the undesired outcome occurring, as determined through the consequence analysis (Asset Criticality).

Figure B-1 below summarises the framework for calculating the ‘risk costs’, which has been applied on our asset portfolio considered to need replacement or refurbishment.

Figure B-1 Risk cost calculation



Economic justification of repx to address an identified need is supported by risk monetised benefit streams, to allow the costs of the project or program to be assessed against the value of the avoided risks

³⁷ [Industry practice application note - Asset replacement planning, AER January 2019](#)

and costs. The major quantified risks we apply for repex justifications include asset failures that materialise as:

- bushfire risk;
- safety risk;
- environmental risk;
- reliability risk; and
- financial risk.

The risk categories relevant to this RIT-T are explained in Section 2.3.

Further details are available in our [Network Asset Risk Assessment Methodology](#).

Appendix C Asset Health and Probability of Failure

The first step in calculating the PoF of an asset is determining the asset health and associated effective age,³⁸ which considers that:

- an asset consists of different components, each with a particular function, criticality, underlying reliability, life expectancy and remaining life - the overall health of an asset is a compound function of all of these attributes;
- key asset condition measures and failure data provides vital information on the current health of an asset, where the 'current effective age' is derived from asset information and condition data;
- the future health of an asset (health forecasting) is a function of its current health and any factors causing accelerated (or decelerated) degradation or 'age shifting' of one or more of its components – such moderating factors can represent the cumulative effects arising from continual or discrete exposure to unusual internal, external stresses, overloads and faults; and
- 'future effective age' is derived by moderating 'current effective age' based on factors such as, external environment/influence, expected stress events and operating/loading condition.

The PoF is the likelihood that an asset will fail during a given period resulting in a particular adverse event, e.g., equipment failure, pole failure, broken overhead conductor.

The outputs of the PoF calculation are one or more probability of failure time series which provide a mapping between the effective age and the yearly probability of failure value for a given asset class. This analysis is performed by generating statistical failure curves, normally using Weibull analysis, to determine a PoF time series set for each asset that gives a probability of failure for each further year of asset life. This establishes how likely it is that the asset will fail over time.

The Weibull parameters which represent the probability of failure curve for key transmission line components are summarised in Table C-1 below.

Further details are available in our [Network Asset Health Methodology](#).

³⁸ Apparent age of an asset based on its condition.

Table C-1 Weibull parameters for asset components

Asset component	Weibull parameters	
	η	β
Structure - Towers C1	3901	1.32
Structure - Towers C2	879.4	3.1
Structure - Towers C3	270.9	2.17
Structure - Towers C4	141.2	2.71
Insulators - Non Ceramic Insulators	26.55	3.232
Insulators - Porcelain Disc - Low corrosion	261.7	4.581
Insulators - Porcelain Disc - High corrosion	173.7	4.763
Conductor Fittings - C1/C2	127.4	4.376
Conductor Fittings - C3/C4	64.24	10.13
Earthwire Fittings - C1/C2	116.5	5.198
Earthwire Fittings - C3/C4	66.61	10.98

Note: C1 (Very Low), C2 (Low), C3 (Medium) and C4 (High) relate to atmospheric corrosion zones based on Australian Standard AS 4312-2008.